



ANNUAL WATER QUALITY REPORT

Muskegon County Eastside Water System

Serving Muskegon Charter Township

*Muskegon County Department of Public Works
Phone (231) 724-6411 FAX (231) 724-6118*

SYSTEM OVERVIEW

The Muskegon Water Filtration Plant is a conventional water treatment plant with a capacity of 40 million gallons per day. Customers include not only the City of Muskegon, but also Muskegon Township, North Muskegon, Roosevelt Park, Fruitport Township, Norton Shores and the County Northside system.

Your water comes from Lake Michigan. The state performed an assessment of our source water in 2003 to determine the susceptibility or the relative potential of contamination. The susceptibility rating is on a six-tiered scale from very low to high based primarily on geologic sensitivity, water chemistry and contaminant sources. The susceptibility of our source water is moderately high.

Water Quality Exceeds Mark!

Dear Customer,

We are pleased to report that the water we treat has never had a violation of a contaminant level or of any other water quality standard.

This report contains a summary of the quality of the water provided to you during 2017 and details where our water comes from, what it contains, and the risks our water testing and treatment are designed to prevent.

Muskegon Water Filtration Plant technicians are committed to providing you with the safest and most reliable water supply. Informed consumers are our best allies in maintaining safe drinking water.

Our state certified lab runs over 8,000 tests a year and include collecting water samples at various stages of the treatment process as well as throughout the distribution system. These samples are analyzed for many different chemical and microbiological parameters. Our sophisticated lab equipment can detect substances at very minute levels. Drinking water, including bottled water, may reasonably be expected to contain at least

small amounts of some contaminants. The presence of contaminants does not necessarily indicate our water poses a health risk.

For more information about contaminants and potential health effects, call the USEPA's Safe Drinking Water Hotline at (800) 426-4791.



Muskegon Water Plant treated over 4.0 billion gallons of water in 2018.

Customer Views

Welcome!

! GET INVOLVED !

Meetings that deal with decisions about our source water are conducted through the Muskegon Conservation District at 231-773-0008

Consult the Web site at **www.shorelinecity.com** or contact the treatment plant at 231-724-4106

For further information, see U.S.Environmental Protection Agency (EPA) water information at **www.epa.gov/safewater**

Is a water treatment device needed for my home?

The water we deliver to our customers is safe to drink as determined by federal and state drinking water standards. We caution those who choose to use treatment devices in their homes to maintain them in accordance with the manufacturer's recommendations. A poorly maintained treatment system can become a breeding ground for bacteria.

LEAKS

Leaks are expensive! If we suspect a leak in your water service, we will notify you in writing and possibly make a site visit. Please, for your benefit, do not ignore leak notices.

You Can Help!

DON'T POUR petroleum based oils, paints, solvents, weed or bug killers, undiluted industrial strength cleaning products DOWN THE DRAIN.

Take all hazardous chemicals to a hazardous waste collection site for proper disposal. Contact our office for details at 231-724-6001. Use environmentally friendly shampoos and detergents; (look for low phosphate or phosphate-free products). Use natural gardening techniques to avoid over-use of pesticides and fertilizers which may run off into streams and lakes.

For more information, contact Greg Leverence, Household Hazardous Waste coordinator at 231-724-6001.

◆ TREATED WATER QUALITY CHART ◆

Listed below are the water quality parameters for the Muskegon County Eastside Water System's drinking water during the reporting period of 2017. All are BELOW allowed levels. Not listed are the hundreds of other contaminants for which we tested that were NOT detected.

Regulated at the Treatment Plant

SUBSTANCE	HIGHEST LEVEL ALLOWED (EPA's MCL's)	HIGHEST LEVEL DETECTED	IDEAL GOAL (EPA's MCLG's)	SOURCE OF CONTAMINANT	VIOLATION YES / NO
BARIUM	2 PPM	0.02 PPM	2 PPM	Discharge from Drilling Wastes	No
NITRATE	10 PPM	0.0 PPM	0	Erosion of natural deposits	No
TOC	TT	*2.88PPM	N/A	Naturally present in environment	No
TURBIDITY	TT	0.08 NTU	N/A	Lake Sediment	No
FLUORIDE	4.0 PPM	0.85 PPM	1.0 PPM	Additive	No

*TOC (total organic carbon) is measured quarterly. Because we remove 25% of the TOC from our source water, we are in compliance. Turbidity is a measure of the cloudiness of the water. We monitor turbidity because it is a good indicator of water quality.

Regulated in the Distribution System

SUBSTANCE	HIGHEST LEVEL ALLOWED (EPA's MCL's)	HIGHEST LEVEL DETECTED AS RAA	IDEAL GOAL (EPA's MCLG's)	SOURCE OF CONTAMINANT	VIOLATION YES / NO
MAX. RESIDUAL DISINFECTANT LEVEL	4 PPM (MRDL)	1.07 PPM (RAA)	N/A	Disinfectant (Chlorine)	No
TOTAL TRIHALOMETHANES	80 PPB (AVG)	34.7 PPB (RAA)	N/A	Disinfection Byproduct	No
HALOACETIC ACID	60 PPB	17.8 PPB (RAA)	N/A	Disinfection Byproduct	No

Detection range: Total Trihalomethanes 23.3 PPB to 44.6 PPB, Haloacetic Acid 13 PPB to 24 PPB. MRDL 0.02 PPM to 1.39 PPM

Unregulated Contaminants

SUBSTANCE	HIGHEST LEVEL ALLOWED (EPA's MCL's)	HIGHEST LEVEL DETECTED	IDEAL GOAL (EPA's MCGL's)	SOURCE OF CONTAMINANT
SODIUM	NOT REGULATED	11 PPM	N/A	Naturally Occurring Mineral

Unregulated contaminants are those for which EPA has not established standards. The purpose of monitoring is to assist the EPA in determining occurrence and whether future regulation is warranted. Other unregulated trace contaminants found in our water and measured in micrograms per liter are: (At tap) Chlorate, 225; Hexavalent Chromium, 0.24; Total Strontium, 122; Total Vanadium, 0.25; Total Molybdenum, 1.1. (Distribution) Chlorate, 222; Hexavalent Chromium, 0.15; Total Strontium, 124; Total Vanadium, 0.28; Total Molybdenum, 1.0.

Regulated at the Customers' Tap

SUBSTANCE	ACTION LEVEL	MAX. DETECTED	90TH PERCENTILE	MCLG	SOURCE
LEAD	15 PPB (AL)	22 PPB	8.0 PPB	0	Plumbing
COPPER	1300 PPB (AL)	460 PPB	300 PPB	1300 PPB	Plumbing

ONE of the 20 sites tested exceeded the action level (AL) for lead. Zero of the 20 sites tested for copper exceeded the action level (AL) for copper. Testing was last performed in June and August 2017.

If present, elevated levels of lead can cause serious health problems, especially for pregnant women and young children. Lead in drinking water is primarily from materials and components associated with service lines and home plumbing. The Muskegon County Eastside Water System is responsible for providing high quality drinking water, but cannot control the variety of materials used in plumbing components. When your water has been sitting for several hours, you can minimize the potential for lead exposure by flushing your tap for 30 seconds to 2 minutes before using the water for drinking or cooking. If you are concerned about lead in your drinking water, you may wish to have your water tested. Information on lead in drinking water, testing methods and steps you can take to minimize exposure is available from the Safe Drinking Water Hotline at 1-800-426-4791 or at <http://water.epa.gov/drink/info/lead>.

DEFINITIONS

MAXIMUM CONTAMINANT LEVEL (MCL) - The highest level of a contaminant that is allowed in drinking water. MCLs are set as close to the MCLGs as feasible using the best available treatment technology.

MAXIMUM CONTAMINANT LEVEL GOAL (MCLG) - The level of a contaminant in drinking water below which there is no known or expected risk to health. MCLGs are set by the U.S. EPA and allow for a margin of safety.

MAXIMUM RESIDUAL DISINFECTANT LEVEL (MRDL) - The highest level of a disinfectant allowed in drinking water. There is convincing evidence that addition of a disinfectant is necessary for control of microbial contaminants.

MAXIMUM RESIDUAL DISINFECTANT LEVEL GOAL (MRDLG) - The level of a drinking water disinfectant below which there is no known or expected risk to health. MRDLGs do not reflect the benefits of the use of disinfectants to control microbial contaminants.

PPM (mg/l) - One part per million

PPB (µg/l) - One part per billion.

ACTION LEVEL (AL) - The concentration of a contaminant that triggers treatment or other requirement that a water system must follow. Action Levels are reported at the 90th percentile for homes at greatest risk.

NTU - Nephelometric Turbidity Units.

TT - Treatment Technique—a required process intended to reduce the levels of a contaminant

RAA - Running Annual Average

MRDL - The highest level of a disinfectant allowed in drinking water

Sources Of Drinking Water

The sources of drinking water (both tap water and bottled water) include rivers, lakes, ponds, reservoirs, springs and wells. Our water comes from Lake Michigan. As water travels over the surface of the land and through the ground, it dissolves naturally occurring minerals and in some cases, radioactive material and can pick up substances from the presence of animals or from human activity.

Contaminants which may be present in source water include:

- * **Microbial contaminants**, such as viruses and bacteria which may come from sewage treatment plants, septic systems, agricultural livestock operations and wildlife.
- * **Inorganic contaminants**, such as salts and metals which can be naturally occurring or result from urban stormwater runoff, industrial or domestic wastewater discharges, oil and gas production, mining or farming.
- * **Pesticides and herbicides**, which may come from a variety of sources such as agricultural and residential usage.
- * **Radioactive contaminants**, which are naturally occurring or the result of oil and gas production and mining activities.
- * **Organic chemical contaminants**, including synthetic and volatile organic chemicals which are byproducts of industrial processes and petroleum production and can also come from gas stations, urban runoff and septic systems. In order to ensure that tap water is safe to drink, EPA prescribes regulations that limit the amount of certain contaminants in water provided by public water systems. Food and Drug Administration regulations establish limits for contaminants in bottled water which provide the same protection for public health.

Cryptosporidium

Cryptosporidium is a microscopic organism that, when ingested, can result in diarrhea, fever and other gastrointestinal symptoms. The Muskegon Water Filtration Plant has tested for **Cryptosporidium** in both Lake Michigan and in the water we treat. We have never detected it in our treated water. The organism is present in Lake Michigan and comes from animal wastes in the watershed. Cryptosporidium is eliminated by an effective treatment combination including filtration, sedimentation and disinfection.

Water Quality Concerns

Some people may be more vulnerable to contaminants in the drinking water than the general population. Immuno-compromised persons, such as persons with cancer undergoing chemotherapy, persons who have undergone organ transplants, people with HIV/AIDS or other immune system disorders, some elderly persons and infants can be particularly at risk for infections. These people should seek advice about drinking water from their health care providers. Environmental Protection Agency and Centers For Disease Control guidelines on appropriate means to lessen the risk of infection by Cryptosporidium and other microbial contaminants are available from the EPA's safe drinking Water Hotline at (800) 426-4791.

Infants and children who drink water containing lead in excess of the action level could experience delays in their physical or mental development. Children could show slight deficits in attention span and learning abilities. Adults who drink this water over many years could develop kidney problems or high blood pressure.

Sustainability

Sustainability comes in many shapes and sizes; it can be anything from teaching children how to read or planting a garden, to companies choosing to use recycled materials to create their product or using only renewable energy. In all respects, sustainability is a conscious effort that focuses on maintaining resources of today without compromising the availability of future resources to help empower future community success. With this goal in mind, Muskegon County government is making that conscious effort by developing a Sustainability Plan with funding from MDEQ's Pollution Prevention grant. This plan will outline goals based on social equity, environmental integrity and economic prosperity to help guide Muskegon County government's future endeavors. More details of the Sustainability Plan will be forthcoming—keep a lookout at <https://www.co.muskegon.mi.us/534/Sustainability>! To learn more about Muskegon County's sustainability efforts and see how we measure up to the rest, visit www.muskegonasc.org at the Prosperity Index tab. Let's make the effort to empower our community's success — together!